

VYPRODUKOVANÉ EMISIE ZA ROK 2016

Kompresorová stanica 1 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/rok		PRH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NOx	CO	NOx	CO	NOx
NP	9,71	13,8	22,33	33,09	100	75
CR1	4,51	47,53	3,91	55,31	100	75
CR3	8,44	36,28	8,34	46,68	100	75
CR4	6,43	32,18	9,79	58,34	100	75
R5	7,81	20,74	11,61	31,87	100	75
R6	6,11	12,78	15,11	31,31	100	75
GT 750 č. 17	1,13	22,36	10,80	214,00	100	300
GT 750 č. 18	0,42	22,94	5,00	272,00	100	300
GT 750 č. 19	0,34	3,72	20,20	220,00	100	300
GT 750 č. 20	4,49	28,86	37,00	238,00	100	300
GT 750 č. 21	0,55	6,23	18,00	203,70	100	300
GT 750 č. 22	0,84	14,05	11,40	190,00	100	300
GT 750 č. 24	2,27	21,09	26,50	246,50	100	300

Kompresorová stanica 2 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/rok		PRH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NOx	CO	NOx	CO	NOx
CR1	0,01	0,02	-	-	100	150
CR2	0,05	0,15	-	-	100	150

Kompresorová stanica 3 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/rok		PRH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NOx	CO	NOx	CO	NOx
NP1	0,01	0,09	8,25	54,86	100	75
NP2	0,13	0,19	17,04	37,16	100	75
R1	1,73	1,43	38,87	45,16	100	75
R2	4,02	3,48	40,13	40,15	100	75

Kompresorová stanica 4 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/rok		PRH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NOx	CO	NOx	CO	NOx
NP1	0,65	0,41	-	-	100	75
NP2	0,04	0,29	2,01	306,72	100	370
NP3	0,01	0,29	11,60	316,04	100	370
NP4	0,01	0,28	10,31	304,10	100	370

Vysvetlivky

PRH Priemerná ročná hodnota