

VYPRODUKOVANÉ EMISIE APRÍL 2017

Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP	0,319	0,428	27,34	36,50	100	75
CR1	0,315	3,701	3,23	58,60	100	75
CR3	0,646	3,676	5,85	55,01	100	75
CR4	1,056	8,204	6,89	63,19	100	75
R5	-	-	-	-	100	75
R6	1,299	3,990	10,27	31,62	100	75

Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	75
R1	1,500	1,810	42,77	49,81	100	75
R2	0,296	0,156	61,88	40,17	100	75

Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m ³)		Emisný limit (mg/m ³)	
	CO	NO _x	CO	NO _x	CO	NO _x
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

Vysvetlivky

PMH Priemerná mesačná hodnota