

## VYPRODUKOVANÉ EMISIE JANUÁR 2017

### Kompresorová stanica 01 Veľké Kapušany

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP	1,821	1,686	54,87	49,51	100	75
CR1	2,319	8,947	12,67	62,25	100	75
CR3	0,369	0,547	34,06	59,78	100	75
CR4	0,349	1,430	12,60	62,99	100	75
R5	-	-	-	-	100	75
R6	2,874	4,366	20,47	28,66	100	75

### Kompresorová stanica 02 Jablonov nad Turňou

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
CR1	-	-	-	-	100	150
CR2	-	-	-	-	100	150

### Kompresorová stanica 03 Veľké Zlievce

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	-	-	-	-	100	75
NP2	-	-	-	-	100	75
R1	-	-	-	-	100	75
R2	-	-	-	-	100	75

### Kompresorová stanica 04 Ivanka pri Nitre

PLYNOVÁ TURBÍNA	t/mesiac		PMH (mg/m <sup>3</sup> )		Emisný limit (mg/m <sup>3</sup> )	
	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>	CO	NO <sub>x</sub>
NP1	0,025	0,002	-	-	100	75
NP2	-	-	-	-	100	370
NP3	-	-	-	-	100	370
NP4	-	-	-	-	100	370

#### Vysvetlivky

**PMH** Priemerná mesačná hodnota